



**PAVUS, a.s., Prosecká 412/74, 190 00 Praha 9 – Prosek, Czech Republic
Notified Body 1391 Authorization No. SPR/030/4000/24-12 from 16th July 2024**

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1391-CPR-2025/0023

In compliance with Regulation (EU) No. 305/2011 of the European Parliament and of the Council of 9 March 2011 (the Construction Product Regulation or CPR), this certificate applies to the construction product:

Fire damper FDML

To be used in conjunction with partitions to maintain fire compartments in heating, ventilating and air conditioning installations.

placed on the market under the name or trade mark of:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic, ID. No. 26718405

and produced in the manufacturing plant:

MANDÍK, a.s.

Dobříšská 550, 267 24 Hostomice, Czech Republic

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard

EN 15650:2010

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This Certificate was first issued on 19th March 2018 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.

This Certificate replaces and cancels Certificate of Constancy of Performance No. 1391-CPR-2020/0130/O1 of 30th December 2021 issued by NB 1391.

Prague 21st March 2025



Jan TRIPES, MBA
executive director – NB 1391

Technical parameters of the assessed product *)

Nominal dimensions: Min: 200×300 mm. Max: 1000×1000 mm

Damper blade thickness: 40 mm

Construction length: 150 mm

Materials used: Galvanised / stainless / painted steel sheet metal

Actuators and thermal sensing elements:

- Servo actuator Belimo BFL/BFN/BF, with thermoelectric sensor (trigger temperature 72/95/120/140°C)
- Servo actuator Gruner 340(C)TA/360(C)TA with thermoelectric sensor (trigger temperature 72/95°C)

Aerodynamic characteristics in accordance with EN 1751

- Leakage through damper body: **Class ATC 4**
- Leakage through damper blade: **Class 3**

Test underpressure: **300 Pa**

Fire resistance classification in accordance with EN 13501-3+A1:2009*):

EI 60 (ve ho) S [V/H]
EI 90 (ve) S [V/H] / E 120 (ve) S [V/H]
EI 90 (ho) S [H] / E 120 (ho) S [H]

Assessed product performance

Essential characteristics	Requirement clauses in EN 15650	Findings
Nominal activation conditions/sensitivity: - sensing element load bearing capacity - sensing element response temperature	4.2.1.2 4.2.1.2.3 4.2.1.2.2	Conforms EN 15650, 4.2.1.2 Conforms EN 15650, 5.2.5 ISO 10294-4:2001, 4.2
Response delay (response time): - closure time	4.2.1.3	Conforms EN 15650, 5.2.4 Response time < 2 min
Operational reliability: - cycling	4.3.1 a)	Conforms EN 15650, 4.3.1 a) 50 cycles before fire test finished
Fire resistance:		
Integrity	4.1.1, a)	E
Insulation	4.1.1, b)	EI
Smoke leakage	4.1.1, c)	EIS
Mechanical stability (Under E)	4.1.1, a)	-
Maintenance of the cross section (Under E)	4.1.1, a)	-
Durability of response delay: - sensing element response to temperature and load bearing capacity	4.2.1.2.2 4.2.1.2.3	Conforms EN 15650, 4.2.1.2
Durability of operational reliability: - open and closing cycle tests	4.3.3.2	Conforms EN 15650 4.3.3.2, Belimo – C.3.2 – C _{10.000} (10.000+100+100 cycles) Gruner – C.3.2 – C _{10.000} (10.000+100+100 cycles)
Protection against corrosion	4.2.2	Conforms EN 15650, 4.2.2 Damper fully operational after test

*) Detailed technical parameters and conditions of the final classification according to EN 13501-3+A1:2009 are stated in the Assessment Report of Performance of the Construction product No. P-1391-CPR-2025/0023 of 21st March 2025.




Jan TRIPES, MBA
 executive director – NB 1391